

Portable Appliance Test Certificate

Company: Quality Discos

Serial Number: 09A-0715

Test Date: 28/05/2011

enquiries@helpitservices.co.uk
Testing Machine: PrimeTest 100

Calibration Date: 20/04/2011

Testers Name: Hugh McGuiness

www.helpitservices.co.uk

Appliance No Lead No	Visual	Polarity	Plug Condition	Test Class	Earth Bond Ω	Insulation Test M Ω	Leak Test MA	Overall Pass/Fail	Appliance Description
1	Pass	Pass	Pass	2	-	19.99	0.10	Pass	D630 Laptop
2	Pass	Pass	Pass	2	-	19.99	0.11	Pass	E5500 Laptop
3	Pass	Pass	Pass	2	-	19.99	0.10	Pass	HDD 1
4	Pass	Pass	Pass	2	-	19.99	0.10	Pass	HDD 2
5	Pass	Pass	Pass	2	-	19.99	0.10	Pass	DMC2 Controller
6	Pass	Pass	Pass	2	-	19.99	0.11	Pass	Pioneer DJM 5000 Mixer
7	Pass	Pass	Pass	2	-	19.99	0.10	Pass	AKG Radio Mic
8	Pass	Pass	Pass	1	0.06	19.99	0.10	Pass	Show Director Switch unit
9	Pass	Pass	Pass	2	-	19.99	0.10	Pass	KAM Radio Mic
10	Pass	Pass	Pass	1	0.02	19.99	1.4	Pass	Crown XTI 1000
11	Pass	Pass	Pass	1	0.02	19.99	1.4	Pass	Crown XTI 4000
12	Pass	Pass	Pass	1	0.02	19.99	0.75	Pass	iMove 7s Moving Head Light
13	Pass	Pass	Pass	1	0.02	19.99	0.75	Pass	iMove 7s Moving Head Light
14	Pass	Pass	Pass	1	0.07	19.99	0.59	Pass	iMove 7s Moving Head Light
15	Pass	Pass	Pass	1	0.07	19.99	0.67	Pass	iMove 7s Moving Head Light
16	Pass	Pass	Pass	2	-	19.99	0.11	Pass	Spot light lighting box
17	Pass	Pass	Pass	1	0.11	19.99	0.10	Pass	LED Star cloth
18	Pass	Pass	Pass	1	0.16	19.99	0.19	Pass	Tri LED master
19	Pass	Pass	Pass	1	0.11	19.99	0.21	Pass	Tri LED
20	Pass	Pass	Pass	1	0.16	19.99	0.19	Pass	Rivo 4
21	Pass	Pass	Pass	1	0.14	19.99	0.10	Pass	Dualize Lighting effect
22	Pass	Pass	Pass	1	0.02	19.99	0.20	Pass	KAM Powerbar
23	Pass	Pass	Pass	1	0.2	19.99	1.28	Pass	Logic XP15 Speaker 1
24	Pass	Pass	Pass	1	0.13	19.99	1.28	Pass	Logic XP15 Speaker 2
25	Pass	Pass	Pass	1	0.03	19.99	0.10	Pass	Show Director Relay unit

