

## Portable Appliance Test Certificate

Company: Quality Discos Department: N/A  
 Testing Machine: PrimeTest 100 Serial Number: 09A-0715

Test Date: 20/04/2010  
 Testers Name: Hugh McGuiness

enquiries@helpitservices.co.uk  
 www.helpitservices.co.uk

Appliance No Lead No	Visual	Polarity	Plug Condition	Test Class	Earth Bond $\Omega$	Insulation Test M $\Omega$	Leak Test MA	Overall Pass/Fail	Appliance Description
000001	Pass	Pass	Pass	2	-	19.99	0.10	Pass	Maxtor Hard Drive
000002	Pass	Pass	Pass	2	-	19.99	0.10	Pass	Maxtor Hard Drive
000003	Pass	Pass	Pass	2	-	19.99	0.10	Pass	Dell D630 laptop
000004	Pass	Pass	Pass	1	0.04	19.99	0.12	Pass	QTX-LS01 Laser
000005	Pass	Pass	Pass	1	0.09	19.99	0.40	Pass	Crown XS500 Amplifier
000006	Pass	Pass	Pass	1	0.01	19.99	1.28	Pass	Crown XT11000
000007	Pass	Pass	Pass	1	0.04	19.99	1.4	Pass	Crown XT11000
000008	Pass	Pass	Pass	1	0.01	19.99	0.10	Pass	Kam Laser
000009	Pass	Pass	Pass	2	-	19.99	0.10	Pass	Fan
000010	Pass	Pass	Pass	1	0.03	19.99	0.10	Pass	Show Ditecor Relay Unit
000012	Pass	Pass	Pass	2	-	19.99	0.10	Pass	iLead DMX Controller
000013	Pass	Pass	Pass	1	0.15	19.99	0.10	Pass	NJD Starcloth Controller
000014	Pass	Pass	Pass	2	-	19.99	0.10	Pass	USB Hub
000015	Pass	Pass	Pass	2	-	19.99	0.10	Pass	Total Control MIDI Controller
000017	Pass	Pass	Pass	1	0.01	19.99	0.60	Pass	Dell 19" Computer Monitor
000018	Pass	Pass	Pass	2	-	19.99	0.10	Pass	Alesis Multimix 12FX Mixer
000019	Pass	Pass	Pass	1	0.02	19.99	0.10	Pass	LEDj56 Par Can
000020	Pass	Pass	Pass	1	0.01	19.99	0.10	Pass	LEDj56 Par Can
000021	Pass	Pass	Pass	1	0.03	19.99	0.40	Pass	Acme Falcon HID150
000022	Pass	Pass	Pass	1	0.04	19.99	0.10	Pass	Acme Super Scimitar
000023	Pass	Pass	Pass	1	0.03	19.99	0.10	Pass	Acme Super Scimitar
000024	Pass	Pass	Pass	1	0.07	19.99	0.55	Pass	iMOVE 7s Moving Head Light
000025	Pass	Pass	Pass	1	0.07	19.99	0.57	Pass	iMOVE 7s Moving Head Light
000026	Pass	Pass	Pass	2	-	19.99	0.10	Pass	AKG SR400 Radio Reciever
000028	Pass	Pass	Pass	2	-	19.99	0.10	Pass	Cortex HDC1000

## Portable Appliance Test Certificate

**Company:** Quality Discos      **Department:** N/A  
**Testing Machine:** PrimeTest 100      **Serial Number:** 09A-0715

**Test Date:** 20/04/2010  
**Testers Name:** Hugh McGuiness

**enquiries@helpitservices.co.uk**  
**www.helpitservices.co.uk**

Appliance No Lead No	Visual	Polarity	Plug Condition	Test Class	Earth Bond Ω	Insulation Test MΩ	Leak Test MA	Overall Pass/Fail	Appliance Description
L01	Pass	Pass	Pass	1	0.02	19.99	-	Pass	IEC lead
L02	Pass	Pass	Pass	1	0.01	19.99	-	Pass	IEC lead
L03	Pass	Pass	Pass	1	0.01	19.99	-	Pass	IEC lead
L04	Pass	Pass	Pass	1	0.09	19.99	-	Pass	IEC lead
L05	Pass	Pass	Pass	1	0.10	19.99	-	Pass	IEC lead
L06	Pass	Pass	Pass	1	0.02	19.99	-	Pass	6x Mains Socket
L07	Pass	Pass	Pass	1	0.02	19.99	-	Pass	6x Mains Socket
L08	Pass	Pass	Pass	1	0.09	19.99	-	Pass	Mains Extension
L09	Pass	Pass	Pass	1	0.03	19.99	-	Pass	Mains Extension
L10	Pass	Pass	Pass	1	0.02	19.99	-	Pass	Mains Adaptor
L11	Pass	Pass	Pass	1	0.02	19.99	-	Pass	Mains Adaptor
L12	Pass	Pass	Pass	1	0.02	19.99	-	Pass	Mains 4x Socket
L13	Pass	Pass	Pass	1	0.02	19.99	-	Pass	Mains 4x Socket
L14	Pass	Pass	Pass	1	0.03	19.99	-	Pass	IEC lead
L15	Pass	Pass	Pass	1	0.03	19.99	-	Pass	IEC lead
L16	Pass	Pass	Pass	1	0.03	19.99	-	Pass	IEC lead
L17	Pass	Pass	Pass	1	0.03	19.99	-	Pass	IEC lead
L18	Pass	Pass	Pass	1	0.03	19.99	-	Pass	IEC lead
L19	Pass	Pass	Pass	1	0.09	19.99	-	Pass	IEC lead
L20	Pass	Pass	Pass	1	0.08	19.99	-	Pass	IEC lead
L21	Pass	Pass	Pass	1	0.07	19.99	-	Pass	IEC lead
L22	Pass	Pass	Pass	1	0.03	19.99	-	Pass	IEC lead
L23	Pass	Pass	Pass	1	0.06	19.99	-	Pass	Mains Extension
L24	Pass	Pass	Pass	1	0.04	19.99	-	Pass	IEC lead
L25	Pass	Pass	Pass	1	0.04	19.99	-	Pass	IEC lead



